



Test Report Summary

Product Information	
Licence Number:	215514
Licensee:	ROTH
Product Identification	DOMOLINE
Test Specifications	
Tested Application:	Water Floor Heating Systems
Temperature Sensor	
- Type:	DeltaDore_NTC100K_14
- Time Constant:	14 Mins
Actuator Identification	ROTH 1135007412
- Type:	Thermal: 2P
Valve Identification	ROTH 1409040413
- Characteristic	2-way/3-way valve: linear
AV Acronym	230V/TA/2P/23WV/L
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy C_A according EN 15500	0.3

03 August 2022

Brussels

A handwritten signature in black ink, appearing to read 'Peter Hug'.

Managing Director Dr. Peter Hug

eu.bac